

24 September 2013

Mr. Josef Šmíd  
Data Centre Operation  
Telefónica Czech Republic, a.s.  
V Lomech 1/2339  
Praha 4 – Chodov  
Ceska Republika  
14900

Re: Tier III Certification of Design Documents for the Telefónica Czech Republic, a.s. – HC Nagáno Praha

Dear Mr. Šmíd,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the Telefónica Czech Republic, a.s. – HC Nagáno Praha as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 12 April 2013 and 26 August 2013.


This Certification recognizes the Telefónica Czech Republic, a.s. – HC Nagáno Praha design, as supporting any planned work on the site infrastructure without disrupting operations, as limited by the stated IT capacity of 1,532 kW comprised of 1,000 kW in Data Room 1 and 442 kW in Data Room 2 and 90 kW in the MMR Room.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

Congratulations on this achievement.

Sincerely,



Vincent Renaud  
Senior Tier Certification Authority

26 August 2013

Mr. Josef Šmíd  
Data Centre Operation  
Telefónica Czech Republic, a.s.  
V Lomech 1/2339  
Praha 4 – Chodov  
Ceska Republika  
14900

Re: Tier III Certification of Design Documents for the Telefónica Czech Republic, a.s. – Datové Centrum Chodov

Dear Mr. Šmíd,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the Telefónica Czech Republic, a.s. – Datové Centrum Chodov as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 12 April 2013 and 26 August 2013.


This Certification recognizes the Telefónica Czech Republic, a.s. – Datové Centrum Chodov design, as supporting any planned work on the site infrastructure without disrupting operations, as limited by the IT capacity of 1,210 kW comprised of 108 kW in each of 10 data halls, 90 kW in data hall T203, and 40 kW in data hall T204. The IT load in data halls T203 and T204 consists only of the LAN/WAN racks.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

Congratulations on this achievement.

Sincerely,



Vincent Renaud  
Senior Tier Certification Authority

1 October 2013

Mr. Josef Šmíd  
Data Centre Operation  
Telefónica Czech Republic, a.s.  
V Lomech 1/2339  
Praha 4 – Chodov  
Česka Republika  
14900

Re: Tier III Certification of Design Documents for the Telefónica Czech Republic, a.s. – HC TKB Hradec Králové

Dear Mr. Šmíd,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the Telefónica Czech Republic, a.s. – HC TKB Hradec Králové as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 12 April 2013 and 30 September 2013.

This Certification recognizes the Telefónica Czech Republic, a.s. – HC TKB Hradec Králové design, as supporting any planned work on the site infrastructure without disrupting operations, as limited by the stated IT capacity of 630 kW comprised of 160 kW in each of Data Room 411, Data Room 405 and Data Room 406 and 150 kW in Data Room 425.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

Congratulations on this achievement.

Sincerely,



Christopher Brown  
Senior Tier Certification Authority